

## Raw Water Before Carbon Addition - PFAS 533 (ng/L)

	PFOA	PFOS	PFHxA	PFHpA	PFNA	PFHxS	PFBS	GenX	6:2 FTSA	PFPeA	PFBA
10/14/2022	Non-Detectable	Non-Detectable	2	Non-Detectable	Non-Detectable	Non-Detectable	Non-Detectable	Non-Detectable	32	3	3
10/15/2022	Non-Detectable	15	3	2							
10/16/2022	Non-Detectable	Non-Detectable	2	Non-Detectable	Non-Detectable	Non-Detectable	Non-Detectable	Non-Detectable	16	3	3
10/17/2022	Non-Detectable	8	2	2							
10/18/2022	Non-Detectable	2	4	Non-Detectable	Non-Detectable	Non-Detectable	Non-Detectable	Non-Detectable	52	5	3
10/19/2022	Non-Detectable	Non-Detectable	4	Non-Detectable	Non-Detectable	Non-Detectable	Non-Detectable	Non-Detectable	34	3	2
10/20/2022	Non-Detectable	2	4	Non-Detectable	Non-Detectable	Non-Detectable	Non-Detectable	Non-Detectable	32	4	2
10/21/2022	Non-Detectable	Non-Detectable	3	Non-Detectable	Non-Detectable	Non-Detectable	Non-Detectable	Non-Detectable	22	3	2
10/22/2022	Non-Detectable	Non-Detectable	3	Non-Detectable	Non-Detectable	Non-Detectable	Non-Detectable	Non-Detectable	22	3	2
10/23/2022	Non-Detectable	Non-Detectable	2	Non-Detectable	Non-Detectable	Non-Detectable	Non-Detectable	Non-Detectable	15	2	2
10/24/2022	Non-Detectable	Non-Detectable	2	Non-Detectable	Non-Detectable	Non-Detectable	Non-Detectable	Non-Detectable	11	2	2
10/25/2022	Non-Detectable	Non-Detectable	2	Non-Detectable	Non-Detectable	Non-Detectable	Non-Detectable	Non-Detectable	13	2	2
10/26/2022	Non-Detectable	2	Non-Detectable	2							
10/27/2022	Non-Detectable	2	Non-Detectable	2	2						
Min	0	0	2	0	0	0	0	0	8	2	2
Max	0	0	2	0	0	0	0	0	52	5	3
<b>Average</b>	<b>#DIV/0!</b>	<b>#DIV/0!</b>	<b>2.00</b>	<b>#DIV/0!</b>	<b>#DIV/0!</b>	<b>#DIV/0!</b>	<b>#DIV/0!</b>	<b>#DIV/0!</b>	24.6	3.2	2.6

Note: Previous Samples for PFAS analyzed by EPA 537.1 did not test for 6:2 FTSA, PFPeA, or PFBA. There is no historical data for these compounds in City of Marinette's drinking water treatment system.

Note (2): Merit Labs has set a reporting limit of 2.0 ng/L. Data for results found below 2.0 ng/L is reported as Non-Detectable by the lab.

Note: All results are in ng/L (parts per trillion)