



Marinette Fire Department

VENDOR TENT REQUIREMENTS

All vendors utilizing tents shall observe the following requirements taken out of the National Fire Protection Association Handbook (NFPA) 102 Chapter 8 and NFPA 701 Chapter 15:

- 1.) Tents shall be labeled as meeting required flame propagation performance requirements.
- 2.) Please carefully observe the tent spacing requirement of **10 feet between stake lines** set forth in these codes.
- 3.) Portable extinguishers shall be a minimum of 2A 10BC which is required by M.M.C. 5.0228. Extinguishers shall be up to date and accessible at all times. For Food Vendors, deep frying operations may also have a class "K" extinguisher present.
- 4.) **NO SMOKING** signs shall be conspicuously posted in all tents. It is up to the vendor to enforce **NO Smoking**.

These code requirements are for the safety of all involved and are not meant to create a burden or hardship for anyone. The Marinette Fire Department respectfully requests your compliance with these codes to ensure a **SAFE** and **ENJOYABLE** event for everyone. If there are any questions please contact us at 715-732-5178.

Thank you,

A handwritten signature in black ink that reads "Chief Jay Heckel". The signature is written in a cursive style.

Chief Jay Heckel